Energy performance certificate (EPC)

Flat 9
103 Mount Wise
NEWQUAY
TR7 2BT

Energy rating
Valid until: 23 March 2026

Certificate number: 0141-3834-7878-9526-2341

Property type Mid-floor flat

Total floor area 54 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's current energy rating is B. It has the potential to be B.

See how to improve this property's energy efficiency



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Walls	Average thermal transmittance 0.15 W/m²K	Very good
Windows	High performance glazing	Very good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Time and temperature zone control	Very good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Air tightness	Air permeability 2.6 m³/h.m² (as tested)	Very good
Roof	(other premises above)	N/A
Floor	(other premises below)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 85 kilowatt hours per square metre (kWh/m2).

About primary energy use

How this affects your energy bills

An average household would need to spend £279 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £0 per year if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2016** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 609 kWh per year for heating
- 1,812 kWh per year for hot water

Impact on the environment

This property's current environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	0.8 tonnes of CO2
This property's potential production	0.8 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

The assessor did not make any recommendations for this property.

Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mark Russell
Telephone	01209 614202
Email	mark.russell@cornwall.gov.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008722
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	24 March 2016
Date of certificate	24 March 2016
Type of assessment	▶ <u>SAP</u>

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <u>dluhc.digital-services@levellingup.gov.uk</u> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

<u>Help (/help) Accessibility (/accessibility-statement) Cookies (/cookies)</u>
<u>Give feedback (https://forms.office.com/e/hUnC3Xq1T4) Service performance (/service-performance)</u>

OGL

All content is available under the \underline{Open} $\underline{Government}$ $\underline{Licence}$ $\underline{v3.0}$ ($\underline{https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/)}$, except where otherwise stated



ht (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-frameworl