

Energy performance certificate (EPC)

85 Suckling Green Lane
Codsall
WOLVERHAMPTON
WV8 2BY

Energy rating

C

Valid until: **2 October 2033**

Certificate number: **2165-3014-7201-3447-1204**

Property type

Detached bungalow

Total floor area

95 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's current energy rating is C. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		
81-91	B		86 B
69-80	C	70 C	
55-68	D		
39-54	E		
21-38	F		
1-20	G		

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Poor
Wall	Solid brick, with internal insulation	Very good
Wall	Cavity wall, as built, insulated (assumed)	Very good
Roof	Pitched, 300 mm loft insulation	Very good
Roof	Flat, insulated	Good
Roof	Flat, insulated (assumed)	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Floor	Solid, no insulation (assumed)	N/A
Floor	Solid, insulated (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 212 kilowatt hours per square metre (kWh/m²).

How this affects your energy bills

An average household would need to spend **£1,861 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £443 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 11,576 kWh per year for heating
- 2,134 kWh per year for hot water

Impact on the environment

This property's current environmental impact rating is D. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year. CO₂ harms the environment.

This property produces 3.6 tonnes of CO₂

This property's potential production 1.7 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Carbon emissions

An average household produces 6 tonnes of CO₂

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Internal or external wall insulation	£4,000 - £14,000	£217
2. Floor insulation (suspended floor)	£800 - £1,200	£147
3. Solar water heating	£4,000 - £6,000	£80
4. Solar photovoltaic panels	£3,500 - £5,500	£654

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme](https://www.gov.uk/apply-boiler-upgrade-scheme) (<https://www.gov.uk/apply-boiler-upgrade-scheme>). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Alison Brittain
Telephone	07970 980155
Email	agough@equityaccess.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/001510
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	26 September 2023
Date of certificate	3 October 2023
Type of assessment	RdSAP