

Electrical Installation Condition Report

Unique Certificate No. DREAMY-000134-EICR

To comply with:

BS 7671: 2018 (Amendment 2: 2022)
Requirement for Electrical Installations
IET Wiring Regulations Eighteenth Edition

Flat 5/1
24 James Morrison St
Glasgow
Lanarkshire
G1 5PE

Electrical verification undertaken for:

Date inspected: 08 August 2023

Overall assessment: **Satisfactory**

Electrical specification presented by:


Dreamy Electrics

22 Armstrong Rd

Helensbrugh

Argyll and Bute

G84 7UE

 07891231189



Dreamy Electrics



Contents of the Report

1. EICR Report

3. EICR Inspection Schedule

6. Observations
 General, Boards and Circuits

8. Distribution Board Schedules
 Including Circuit Details and Test Results

9. Notes For Recipients

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671 - Requirements for Electrical Installations

DETAILS OF THE CLIENT

Client:	Lomond Letting Agency	Contract Ref (if any):	
Address:	Lomond Letting Agency, 68 East Clyde Street, Helensburgh, Argyll and Bute, G84 7PG		

REASON FOR PRODUCING THIS REPORT

Electrical inspection for tenancy agreement	
Date(s) on which inspection and testing was carried out	08 August 2023

DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier:	Unoccupied	Description of premises:	Domestic
Address:	Flat 5/1, 24 James Morrison St, Glasgow, Lanarkshire, G1 5PE	Estimated age of wiring system:	10 years
		Evidence of additions / alterations:	Not apparent
Date of last inspection:	Not known	If yes, estimate age:	N/A
		Electrical Installation Certificate No or previous Electrical Installation Condition Report No:	Unknown
Installation records available:	N/A	Records held by:	Unknown

EXTENT OF THE INSTALLATION

Extent of the installation covered by this certificate:	Visual and full electrical verification
---	---

LIMITATIONS OF THE INSPECTION AND TESTING

Agreed limitations including the reasons (See Regulation 653.2):	None
Agreed with:	N/A

Operational limitations including the reasons	None
---	------

The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671: 2018 (Amendment 2: 2022).

It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground, have not been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):	
Main supply that has been fitted to the property is fairly standard for the type of property, main earth cable meets the requirements and is giving strong readings. There is no boning in the property which is not an issue as there is no gas, main water feed is plastic and the structural metal used is earthed from the building.	
The Consumer unit is fairly basic providing the minimum protection needed and meets the minimum requirement when it was installed. There could be some significant upgrades to the safety of the installation should this be upgraded. Also due to the change in regulations AFDD's (Ark Fault Detection Device) would be a must if the consumer unit was changed.	
There is no issues with the wiring around the property and all points are giving good readings.	
Overall assessment of the installation in terms of its suitability for continued use:	Satisfactory
An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified	


RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classified as 'Danger present' (Code C1) or 'Potentially dangerous' (Code C2) are acted upon as a matter of urgency.	
Investigation without delay is recommended for observations identified as 'Further investigation required' (code FI).	
Observations classified as 'Improvement recommended' (Code C3) should be given due consideration.	
It is recommended that the installation is further inspected & tested:	before 08 August 2028 or change of tenancy
For the following reason:	In accordance with BS7671


DECLARATION

I/We being the person(s) responsible for the inspection & testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection & testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the extent and limitations stated in this report.

INSPECTED AND TESTED BY:

Name	Graham Meadowcroft	For & on behalf of:	Dreamy Electrics		
Position	Administrator	Address:	22 Armstrong Rd Helensburgh Argyll and Bute G84 7UE 07891231189 dreamyelectrics@gmail.com		
Date	08 August 2023				
Signature					
Enrolment No.:	NAP62912	Branch No.:	01	Accredited Body:	NAPIT

REPORT AUTHORISED FOR ISSUE BY:

Name	Graham Meadowcroft	For & on behalf of:	Dreamy Electrics		
Position	Administrator	Address	22 Armstrong Rd Helensburgh Argyll and Bute G84 7UE 07891231189 dreamyelectrics@gmail.com		
Date	08 August 2023				
Signature					
Enrolment No.:	NAP62912	Branch No.:	01	Accredited Body:	NAPIT

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements	TN-S	TN-C-S	✓	TT	TN-C	IT	
Number and Type of Live Conductors	A.C./D.C.	A.C.		No. of phases	1-Phase (2-wire)		
Nature of Supply Parameters							
Nominal voltage(s), U_0	230V	Nominal frequency, f	50Hz	Number of supplies	1	Phase sequence confirmed:	✓
U	N/A	External earth fault loop impedance, Z_e	0.31Ω	Prospective fault current, I_{pf}	0.85kA	Supply polarity confirmed:	✓
Primary Supply Overcurrent Protective Device(s)	BS 1362 Fuse [Domestic] N/A			Rated current	100A	Short-circuit capacity	N/A
Other sources of supply:							
Standard TNC-S system installed							

PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of earthing	Supplier's facility	Maximum Demand (Load):	50A				
Method of Fault Protection	ADS						
Main Protective Conductors							
Earthing Conductor	Conductor material	Copper	Conductor csa	10mm ²	Continuity check	✓	
Main protective bonding conductors	Conductor material	Copper	Conductor csa	10mm ²	Continuity check	✓	
Bonding of extraneous-conductive parts	Water installation pipes:	N/A	Gas installation pipes:	N/A	Oil service:	N/A	
	Structural steel:	N/A	Lightning protection:	N/A	N/A		
Main Switch / Switch-Fuse / Circuit-breaker / RCD							
Location	Ground flood cupboard		BS(EN)	BS EN 60947-3 N/A			
	No. of poles	2	Rated voltage	240V	Rated current	100A	
	Fuse rating or setting	N/A	Conductors material	Copper	Conductors csa	2 x 25mm ²	
Front End Residual Current Device details (if applicable):							
RCD type	N/A	Operating current $I_{\Delta n}$	N/A	Operating time @ $I_{\Delta n}$	N/A	Type 'S' RCD (time delayed)	N/A

INSPECTION SCHEDULE SUMMARY

Item No.	Description	Outcome	Item No.	Description	Outcome
1.0	Section 1 - Intake equipment (visual inspection only)	Pass	5.0	Section 5 - Final circuits	Pass
2.0	Section 2 - Presence of adequate arrangements for other sources such as microgenerators	N/A	6.0	Section 6 - Location(s) containing a bath or shower	Pass
3.0	Section 3 - Earthing / Bonding arrangements	Pass	7.0	Section 7 - Other part 7 special installations or locations	N/A
4.0	Section 4 - Consumer unit(s) / Distribution board(s)	Pass	8.0	Section 8 - Prosumer's low voltage electrical installation(s)	N/A
			9.0	Section 9 - Not covered by any BS7671 Inspection Schedule section	Pass

EICR Inspection Schedule

If the schedule item applies to a particular board or circuit, this is shown in the 'Location' column. Further detail can be found in the 'Observations' section.

Item No	Description	Outcome	Location
1 Section 1 - Intake equipment (visual inspection only)			
1.1.1	Distributor/supplier's service cable	✓	
1.1.2	Distributor/supplier's service head	✓	
1.1.3	Distributor/supplier's earthing arrangement	✓	
1.1.4	Distributor/supplier's meter tails	✓	
1.1.5	Distributor/supplier's metering equipment	✓	
1.1.6	Distributor/supplier's isolator (where present)	✓	
1.1.7	For all of 1.1, the person ordering work/dutyholder has been notified of any issues	N/A	
1.2	Consumer's isolator (where present)	✓	
1.3	Consumer's meter tails	✓	
2 Section 2 - Presence of adequate arrangements for other sources such as microgenerators			
2	Presence of adequate arrangements for other sources such as micro-generators (551.6; 551.7)	N/A	
3 Section 3 - Earthing / Bonding arrangements			
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	✓	
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)	N/A	
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)	N/A	
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)	✓	
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)	✓	
3.6	Confirmation of main protective bonding conductor sizes (544.1)	N/A	
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)	✓	
3.8	Accessibility and condition of other protective bonding connections (543.3.1; 543.3.2)	✓	
3	Earthing & bonding arrangements - not covered by any BS7671 item in Section 3	✓	
4 Section 4 - Consumer unit(s) / Distribution board(s)			
4.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)	✓	
4.2	Security of fixing (134.1.1)	✓	
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)	✓	
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)	C3 - Improvement recommended	DB 001
4.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)	✓	
4.6	Presence of main linked switch (as required by 462.1.201)	✓	
4.7	Operation of main switch (functional check) (643.10)	✓	
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (643.10)	✓	
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓	
4.1	Presence of RCD six-monthly test notice, where required (514.12.2)	✓	
4.11	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)	N/A	
4.12	Presence of other required labelling (please specify) (Section 514)	✓	
4.13	Compatibility of protective devices, bases and other components; correct type and rating (No signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)	✓	
4.14	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.3)	✓	
4.15	Protection against mechanical damage where cables enter consumer unit/distribution board (522.8.1; 522.8.5; 522.8.11)	✓	
4.16	Protection against electromagnetic effects where cables enter consumer unit/distribution board/enclosures (521.5.1)	✓	
4.17	RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.5.2; 531.2)	C3 - Improvement recommended	DB 001
4.18	RCD(s) provided for additional protection/requirements - includes RCBOs (411.3.3; 415.1)	✓	
4.19	Confirmation of indication that SPD is functional (651.4)	C3 - Improvement recommended	DB 001
4.2	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓	

Item No	Description	Outcome	Location
4.21	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A	
4.22	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A	
4	Consumer unit(s) / Distribution board(s) - not covered by any BS7671 item in Section 4	✓	
5 Section 5 - Final circuits			
5.1	Identification of conductors (514.3.1)	✓	
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓	
5.3	Condition of insulation of live parts (416.1)	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (to include the integrity of conduits and trunking systems, both metal and plastic) (521.10.1)	✓	
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓	
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓	
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	C3 - Improvement recommended	DB 001
5.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓	
5.1	Concealed cables installed in prescribed zones (refer to: Extent and Limitations) (522.6.202)	✓	
5.11	Cables concealed under floor, above ceilings, or in walls/partitions, adequately protected against mechanical damage (refer to: Extent and Limitations) (522.6.204)	✓	
5.12.1	Provision of additional requirements for protection by RCD not exceeding 30 mA for all socket-outlets of rating 32 A or less, unless an exception is permitted (411.3.3)	✓	
5.12.2	Provision of additional requirements for protection by RCD not exceeding 30 mA for the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓	
5.12.3	Provision of additional requirements for protection by RCD not exceeding 30 mA for cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	✓	
5.12.4	Provision of additional requirements for protection by RCD not exceeding 30 mA for cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	✓	
5.12.5	Provision of additional requirements for protection by RCD not exceeding 30 mA for final circuits supplying luminaires within domestic (household) premises (411.3.4)	C3 - Improvement recommended	DB 001
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓	
5.14	Band II cables segregated/separated from Band I cables (528.1)	✓	
5.15	Cables segregated/separated from communications cabling (528.2)	✓	
5.16	Cables segregated/separated from non-electrical services (528.3)	✓	
5.17.1	Termination of cables at enclosures - indicate extent of sampling in Extent & Limitations of the report (Section 526); Connections soundly made and under no undue strain (526.6)	✓	
5.17.2	Termination of cables at enclosures - indicate extent of sampling in Extent & Limitations of the report (Section 526); No basic insulation of a conductor visible outside enclosure (526.8)	✓	
5.17.3	Termination of cables at enclosures - indicate extent of sampling in Extent & Limitations of the report (Section 526); Connection of live conductors adequately enclosed (526.5)	✓	
5.17.4	Termination of cables at enclosures - indicate extent of sampling in Extent & Limitations of the report (Section 526); Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓	
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2(v))	✓	
5.19	Suitability of accessories for external influences (512.2)	✓	
5.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)	✓	
5.21	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	✓	
5.22	Provision of relevant certification confirming that the electrical installation, or alteration, has been inspected and verified in accordance with Chapter 64	✓	
5	Final circuits - not covered by any BS7671 item in Section 5	✓	
6 Section 6 - Location(s) containing a bath or shower			
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)	N/A	
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	✓	
6.3	Shaver supply units comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	✓	
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)	N/A	
6.5	Low voltage (e.g. 230 V) socket-outlets sited at least 2.5 m from zone 1 (701.512.3)	✓	
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	✓	
6.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	✓	
6.8	Suitability of current-using equipment for particular position within the location (701.55)	✓	

Item No	Description	Outcome	Location
6	Location(s) containing a bath or shower - not covered by any BS7671 item in Section 6	✓	
7 Section 7 - Other part 7 special installations or locations			
7.1	Add any inspection tests made for any special installations or locations present, and mark outcome as appropriate	N/A	
8 Section 8 - Prosumer's low voltage electrical installation(s)			
8.1	Where the installation includes additional requirements and recommendations relating to Chapter 82, mark the outcome as appropriate and add a note in Observations	N/A	
9 Section 9 - Not covered by any BS7671 Inspection Schedule section			
9	Section 9 - Not covered by any BS7671 Inspection Schedule section	✓	

Observations


001 C3 - Improvement recommended

Absence of residual current device protection of circuits for fault protection

Board Reference:
DB 001

Notes:
There is no RCD protection to the first 6 circuits.

Schedule Item contravened:
4.17 - RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.5.2; 531.2)



Internals of consumer unit

002 C3 - Improvement recommended

Circuits supplying luminaries in domestic dwelling, class 2 fittings, No RCD protection

Board Reference:
DB 001

Notes:
No RCD protection for the lighting circuit for the installation.

Schedule Item contravened:
5.12.5 - Provision of additional requirements for protection by RCD not exceeding 30 mA for final circuits supplying luminaires within domestic (household) premises (411.3.4)




Image of layout of consumer unit

003 C3 - Improvement recommended

CU in a domestic household premises is not metal or installed in a non-combustable cabinet, showing NO signs of thermal damage

Board Reference:
DB 001

Notes:
Consumer unit is not fire retardant and should a fire break out within the consumer unit it would not hold the fire back. It would be advised that the consumer unit is replaced with a metal clad version or a metal container is fitted around it.

Schedule Item contravened:
4.4 - Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)



Front of consumer unit

005 C3 - Improvement recommended

No presence of AFDD's

Board Reference:

DB 001

Notes:

Under amendment 2 of the 18th edition wiring regulations it is recommended that AFDD's are installed due to the height of the property.

Schedule Item contravened:

5.7 - Adequacy of protective devices: type and rated current for fault protection (411.3)

004 C3 - Improvement recommended

No presences of surge protection

Board Reference:

DB 001

Notes:

There is no presence of surge protection to this installation and it would be advised that this is added.

Schedule Item contravened:

4.19 - Confirmation of indication that SPD is functional (651.4)




Image of consumer unit

Test Results: DB 001

DB Location:		Supply Derived From:	Main supply	Distribution circuit OCPD BS (EN) / Type:	BS 1362 Fuse [Domestic] N/A	Phase sequence confirmed:		Z _s at DB:		SPD Functionality Confirmed:	
DB Type/No:		Voltage:		OCPD Rating / SCC:	100A / N/AkA	Supply polarity confirmed:		I _{pf} at DB:		Vulnerable circuits and/or installed equipment:	
Designation:		No. of phases:		SPD BS (EN) / Type:		Details of Test Instruments Used					
Tested by:	Graham Meadowcroft	Signed:		Date:	08 Aug 2023	Continuity:		Insulation resistance:		Earth fault loop impedance:	
						RCD:		Earth electrode resistance:		Other:	

Circuit		Conductor Details					Protective device					RCD				Ring Final Circuit Continuity (Ω)			Continuity (Ω)		Insulation Resistance				Z _s	RCD Test Results		Manual AFDD Test Button			
No.	Description	Type of wiring	Reference Method	No. of points	Live (mm ²)	CPC (mm ²)	Max Disc. Time (s)	BS (EN)	Type	Rating (A)	Breaking Cap. (kA)	Maximum Permitted Z (Ω)	BS (EN)	Type	I _{Δn} (mA)	Rating (A)	No. of poles	r ₁ (phase)	r _n (neutral)	r ₂ (cpc)	R1 + R2 (Ω)	R2 (Ω)	Test Voltage	L-L (MΩ)		L-N (MΩ)	L-E (MΩ)		Polarity	Max Measured Z (Ω)	Op. time at I _{Δn} (ms)
1	Electrical Water Heater	PVC T&E	100	2	10	4.0	0.4	60898	B	40	6	1.09	--	--	--	--	--	N/A	N/A	N/A	0.23	N/A	500V	N/A	>500	>500	✓	0.38	--	--	N/A
2	Lower Lever Accessory room Lighting	PVC T&E	100	12	1.0	0.75	0.4	60898	B	6	6	7.28	--	--	--	--	--	N/A	N/A	N/A	1.14	N/A	500V	N/A	>500	>500	✓	1.37	--	--	N/A
3	Ground floor bedroom lights	PVC T&E	100	12	1.0	0.75	0.4	60898	B	6	6	7.28	--	--	--	--	--	N/A	N/A	N/A	0.54	N/A	500V	N/A	>500	>500	✓	0.84	--	--	N/A
4	1st Half upper floor lighting	PVC T&E	100	18	1.0	0.75	0.4	60898	B	6	6	7.28	--	--	--	--	--	N/A	N/A	N/A	1.04	N/A	500V	N/A	>500	>500	✓	1.21	--	--	N/A
5	2nd Half upper lighting	PVC T&E	100	13	1.0	0.75	0.4	60898	B	6	6	7.28	--	--	--	--	--	N/A	N/A	N/A	1.75	N/A	500V	N/A	>500	>500	✓	1.16	--	--	N/A
6	Smoke alarms	PVC T&E	100	3	1.0	0.75	0.4	60898	B	6	6	7.28	--	--	--	--	--	N/A	N/A	N/A	1.02	N/A	500V	N/A	>500	>500	✓	1.22	--	--	N/A
7	Cooker	PVC T&E	100	2	6.0	2.5	0.4	60898	B	32	6	1.37	61008	AC	30	80	2	N/A	N/A	N/A	0.61	N/A	500V	N/A	>500	>500	✓	0.63	18.9	✓	N/A
8	Sockets Ground Floor	PVC T&E	100	12	2.5	1.0	0.4	60898	B	32	6	1.37	61008	AC	30	80	2	0.45	0.43	0.72	0.47	N/A	500V	N/A	>500	>500	✓	0.69	18.9	✓	N/A
9	Sockets Upper Floor	PVC T&E	100	17	2.5	1.0	0.4	60898	B	32	6	1.37	61008	AC	30	80	2	0.53	0.53	0.78	0.54	N/A	500V	N/A	>500	>500	✓	0.72	18.9	✓	N/A
10	Water Heater	PVC T&E	103	2	2.5	1.0	0.4	60898	B	16	6	2.73	61008	AC	30	80	2	N/A	N/A	N/A	0.32	N/A	500V	N/A	>500	>500	✓	0.64	18.9	✓	N/A

Condition Report

Guidance for Recipient

This Report is an important and valuable document which should be retained for future reference.

1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see 'Summary of the Condition of the Installation'). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see 'Observations').
2. This Report is only valid if accompanied by the Inspection Schedule and the Distribution Schedule(s) of circuit details including Test Results.
3. The person ordering the Report should have received the original Report and the inspector should have retained a duplicate.
4. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
5. The sections 'Extent of the Installation' and 'Limitations of the Inspection and Testing' should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in section on Limitations.
7. For items classified in the Observations section as C1 ('Danger present'), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in the Observations section as C2 ('Potentially dangerous'), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in the Observations section that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Recommendations).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in the 'Recommendations' section of the Report.
11. Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be

switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

12. Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

13. Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

14. Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

Glossary of Terms

Abbreviations

ATLP	Access to Live Parts	LSHF/PVCS	Low Smoke Halogen Free PVC Single Cables in Conduit/ Trunking Containmentment
BH	Bulkhead Light Fitting	LSHF/SWA	Low Smoke Halogen Free Steel Wired Armoured Cable
CMET	Consumer Main Earth Terminal	LSHF/T&E	Low Smoke Halogen Free T&E
CPC	Circuit Protective Conductor	LSHF/XLPE/SWA	XLPE Low Smoke Halogen Free Steel Wired Armoured Cable
CSP	Heat Resistant Rubber Flexible Cable	MCB	Miniature Circuit Breaker
DB	Distribution Board	MCCB	Moulded Case Circuit Breaker
DNO	Distribution Network Operator	MEB	Main Equipotential Bonding
EES	Emergency Exit Signs	MET	Main Earth Terminal
EPR	Heat Resistant Rubber Flexible Cable	MICC	Mineral Insulated Copper Cable
ELV	Extra Low Voltage	NT	Not Tested (Dysfunctional)
EML	Emergency Lighting	OCP	Overcurrent Protection
EN 60898	Miniature Circuit Breaker	PSU	Power Supply Unit (via 13A FCU)
EN 60947-2	Moulded Case Circuit Breaker	PVC T&E	PVC/PVC twin and earth cable
EN 60947-3	Switch, disconnecter, or switch-fuse	PVC/SWA	PVC Steel Wired Armoured Cable
EN 61008	Residual Circuit Breaker (without overcurrent protection)	PVCS	PVC Single Cables in Conduit/ Trunking Containmentment
EN 61009	Residual Circuit Breaker (with overcurrent protection)	Radial	Radial Circuit
FCU	13A Fused Connection Unit	RC	Refer to Comments
FIR	Further Investigation Required	RCD	Residual Circuit Device
FP	Fire Rated Protected Cable	RFC	Ring Final Circuit
IP	Ingress Protection	S/O 13A	Socket Outlet
LHS/RHS	Left Hand Side/Right Hand Side	VIR	Vulcanised Indian Rubber
LSF	Low Smoke & Fume Cables	XLPE/SWA	XLPE Steel Wired Armoured Cable

Overcurrent Protective Device Abbreviations

BS (EN)	Type No	Device
60898	B	BS EN 60898 MCB Type B - Miniature Circuit Breaker (Type B)
60898	C	BS EN 60898 MCB Type C - Miniature Circuit Breaker (Type C)
60898	D	BS EN 60898 MCB Type D - Miniature Circuit Breaker (Type D)
61009	B	BS EN 61009 RCBO Type B - Residual Current Device (Type B)
61009	C	BS EN 61009 RCBO Type C - Residual Current Device (Type C)
61009	D	BS EN 61009 RCBO Type D - Residual Current Device (Type D)
3871	1	BS 3871 MCB Type 1 - Miniature Circuit Breaker (Type 1)
3871	2	BS 3871 MCB Type 2 - Miniature Circuit Breaker (Type 2)
3871	3	BS 3871 MCB Type 3 - Miniature Circuit Breaker (Type 3)
3871	4	BS 3871 MCB Type 4 - Miniature Circuit Breaker (Type 4)
61008		BS EN 61008 RCD - Residual Current Device
4293		BS EN 4293 RCD - Residual Current Device
88-2	E	BS 88-2 Fuse System E (Bolted) - High Rupture Capacity Cartridge Fuse
88-2	G	BS 88-2 Fuse System G (Clip-In) - High Rupture Capacity Cartridge Fuse
88-2.2	gG	BS 88-2.2 Fuse (gG) - High Rupture Capacity Cartridge Fuse
88-3	C	BS 88-3 Fuse System C - High Rupture Capacity Cartridge Fuse
88-6	gG	BS 88-6 Fuse (gG) - High Rupture Capacity Cartridge Fuse
1361	2	BS 1361 Fuse Type 2
1362		BS 1362 Fuse (Domestic)
3036		BS 3036 Fuse Rewirable (Semi-Enclosed)
60947-2	MCCB	BS EN 60947-2 MCCB - Moulded Case Circuit Breaker
60947-3		BS EN 60947-3 - Isolator
60947-2	ACB	BS EN 60947-2 ACB - Air Circuit Breaker
N/V		Non-Verifiable
LIM		Limitation (Refer to: Limitations of the Inspection)

British Standard (BS)

British Standard BS 7671: 2018 Amendment 1: 2020 – also known as the IET (Institution of Engineering & Technology) Wiring Regulations (18th Edition) - Requirements for Electrical Installations is the standard against which all electrical installations are assessed.

Certificate

Any electrician installing a new electrical installation (including a single circuit), altering, extending or adapting an existing circuit should issue to their client, or the homeowner, an Electrical Installation Certificate (EIC), or a Minor Electrical Installation Works Certificate (MEW) to confirm the work complies with the requirements of BS 7671 Appendix 6

Circuit

An assembly of electrical equipment (socket outlets, lighting points and switches) supplied from the same origin and protected against overcurrent by the same protective device(s).

Class I Equipment

Equipment in which protection against electric shock does not rely on basic insulation only, but which includes means for the connection of exposed-conductive-parts to a protective conductor in the fixed wiring of the installation. Class I equipment has exposed metallic parts, e.g. the metallic enclosure of washing machine.

Class II Equipment

Class II equipment, such as music systems, television and video players, in which protection against electric shock does not rely on basic insulation only, but in which additional safety precautions such as supplementary insulation are provided, there being no provision for the connection of exposed metalwork of the equipment to a protective conductor, and no reliance upon precautions to be taken in the fixed wiring of the installation.

Class III Equipment

Equipment, for example for medical use, in which protection against electric shock relies on supply at SELV (Safety extra low voltage) and in which voltages higher than those of SELV are not generated. Class III equipment must be supplied from a safety isolating transformer.

Consumer Unit (also known as a fuse board, or distribution board)

A type of distribution board (principally for domestic premises) comprising a co-ordinated assembly for the control and distribution of electrical energy, incorporating manual means of double-pole isolation on the incoming circuit(s) and an assembly of one or more fuses, circuit-breakers, residual current operated devices or signalling and other devices purposely manufactured for such use.

Distribution Board

An assembly containing switching or protective devices (e.g. fuses, circuit-breakers, residual current operated devices) associated with one or more outgoing circuits fed from one or more incoming circuits, together with terminals for the neutral and protective circuit conductors. It may also include signalling and other control devices. Means of isolation may be included in the board or may be provided separately.

Electrical Installation

Any assembly of electrical equipment supplied by a common source to fulfil a specific purpose.

EICR – Electrical Installation Condition Report

An electrical survey, known as an Electrical Installation Condition Report (EICR) will reveal if electrical circuits are overloaded, find potential hazards in the installation, identify defective DIY work, highlight any lack of earthing or bonding and carry out tests on the fixed wiring of the installation. The report will establish the overall condition of all the electrics and state whether it is satisfactory for continued use and should detail any work that might need to be done.

Electrical Safety Regulations

Registered electricians have already helped to improve the standard of electrical work in the UK. A new electrical safety law, often referred to as Part P (of the Building Regulations), has further enhanced the protection of homeowners and reduced the risk of electric shock when using electricity. The law, which applies to England and Wales aims to improve electrical safety in the home and prevent the number of accidents, which are caused by faulty electrical work. The law requires an electrician registered with a government-approved scheme, such as the NICEIC/ECA/NAPIT/ELECSA/STROMA etc., to carry out most electrical work in the home. After completion of any work, your registered electrician will issue you with a Building Regulations Compliance Certificate to prove it meets the required standards of Part P. You can only carry out electrical work yourself if you can inspect and test that it is safe for use. To comply with the law, you must notify your local building control office before you begin any work and pay the appropriate fee for them to inspect the work.

Extension Leads

An extension cable, also known as a power extender, extension cord or an extension lead, is a length of flexible electrical power cable or flex with a plug on one end and one or more sockets on the other end - usually of the same type as the plug. However, use of extension leads should be avoided where possible, as there is a chance of overloading the circuit.

Miniature Circuit Breaker

A device capable of making, carrying and breaking normal load currents, and making and automatically breaking under predetermined conditions, abnormal currents such as short-circuit currents. It is usually required to operate infrequently, although some types are suitable for frequent operation.

Moulded Case Circuit Breaker

A device capable of making, carrying, and breaking normal load currents, and making and automatically breaking under predetermined conditions abnormal currents such as short-circuit currents. It is usually required to operate infrequently, although some types are suitable for frequent operation. It is meant for higher rated current and is commonly used in Industrial applications. It's usual range is 250A-800A.

Overcurrent

Electrical current (in amps) that exceeds the maximum limit of a circuit. May result in risk of fire or shock from insulation damaged from heat generated by overcurrent condition.

Part P

The specific section of the Building Regulations for England and Wales that relates to electrical installations in domestic properties. Part P provides safety regulations to protect householders and requires most domestic electrical work to be carried out by government-registered electricians, or to be inspected by Building Control officers.

PAT - Portable Appliance Testing

Inspection and testing of electrical equipment including portable appliances, moveable equipment, hand held appliances, stationary equipment, fixed equipment/appliances, IT equipment and extension leads.

PLI - Public Liability Insurance

Broad term for insurance which covers liability exposures for individuals and business owners. Homeowners should check that their electrician has public liability insurance, which covers them if someone is accidentally injured by them or their business operation. It will also cover them if they damage your property while on business. The cover should include any legal fees and expenses which result from any claim by you. Homeowners looking to employ trades people to undertake work on their homes should ensure the companies selected have suitable cover – minimum recommendation is £2 million.

Portable equipment

Electrical equipment which is less than 18 kg in mass and is intended to be moved while in operation or which can easily be moved from one place to another, such as a toaster, food mixer, vacuum cleaner, fan heater.

Prospective fault current

The value of overcurrent at a given point in a circuit resulting from a fault between live conductors, or a live conductor and earth.

RCD - Residual Current Device

Residual current device is a safety device that switches off the electricity automatically when it detects an earth fault, providing protection against electric shock (only when rated at 30mA or less).

Ring Final Circuit

A final circuit connected in the form of a ring and connected to a single point of supply.

Voltages:

SELV

Separated Extra-Low Voltage. An extra-low voltage system, which is electrically separated from Earth and from other systems in such a way that a single fault cannot give rise to the risk of electric shock.

Extra-Low Voltage

Normally not exceeding 50 V ac or 120 V ripple-free dc whether between conductors or to earth.

Low Voltage

Low Voltage (50V - 1000V)

mA

Milliamp or 1/1000 part of an amp (0.001 amp)