

# Energy performance certificate (EPC)

Andeley Beacon Hill Road HINDHEAD GU26 6NR	Energy rating <b>E</b>	Valid until: <b>12 April 2033</b>
		Certificate number: <b>7337-5824-7200-0672-5292</b>

## Property type

Detached house

## Total floor area

121 square metres

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be B.

[See how to improve this property's energy performance.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, 100 mm loft insulation	Average
Window	Fully double glazed	Good

Feature	Description	Rating
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

## Primary energy use

The primary energy use for this property per year is 378 kilowatt hours per square metre (kWh/m<sup>2</sup>).

▶ [What is primary energy use?](#)

## Additional information

Additional information about this property:

- Cavity fill is recommended

## Environmental impact of this property

This property's current environmental impact rating is E. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

## An average household produces

6 tonnes of CO<sub>2</sub>

## This property produces

8.1 tonnes of CO<sub>2</sub>

## This property's potential production

2.5 tonnes of CO<sub>2</sub>

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

**Improve this property's energy rating**

▶ [Do I need to follow these steps in order?](#)

---

**Step 1: Increase loft insulation to 270 mm****Typical installation cost**

£100 - £350

**Typical yearly saving**

£95

**Potential rating after completing step 1**50 | E

---

**Step 2: Cavity wall insulation****Typical installation cost**

£500 - £1,500

**Typical yearly saving**

£810

**Potential rating after completing steps 1 and 2**60 | D

---

**Step 3: Floor insulation (solid floor)****Typical installation cost**

£4,000 - £6,000

**Typical yearly saving**

£225

**Potential rating after completing steps 1 to 3**63 | D

## Step 4: Hot water cylinder thermostat

### Typical installation cost

£200 - £400

### Typical yearly saving

£238

### Potential rating after completing steps 1 to 4

66 | D

## Step 5: Replace boiler with new condensing boiler

### Typical installation cost

£2,200 - £3,000

### Typical yearly saving

£598

### Potential rating after completing steps 1 to 5

73 | C

## Step 6: Solar water heating

### Typical installation cost

£4,000 - £6,000

### Typical yearly saving

£105

### Potential rating after completing steps 1 to 6

75 | C

## Step 7: Solar photovoltaic panels, 2.5 kWp

### Typical installation cost

£3,500 - £5,500

## Typical yearly saving

£694

## Potential rating after completing steps 1 to 7

83 | B

## Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

### Estimated energy use and potential savings

Based on average energy costs when this EPC was created:

### Estimated yearly energy cost for this property

£3843

### Potential saving if you complete every step in order

£2071

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

### Estimated energy used to heat this property

Type of heating	Estimated energy used
-----------------	-----------------------

Space heating	18387 kWh per year
---------------	--------------------

Water heating	3455 kWh per year
---------------	-------------------

### Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
--------------------	------------------------

Loft insulation	598 kWh per year
-----------------	------------------

Cavity wall insulation	5100 kWh per year
------------------------	-------------------

## Saving energy in this property

[Find ways to save energy in your home.](#)

### Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

### Assessor's name

Robert Oepkes

---

### Telephone

01189770690

---

### Email

[epc@nichecom.co.uk](mailto:epc@nichecom.co.uk)

---

## Accreditation scheme contact details

### Accreditation scheme

Elmhurst Energy Systems Ltd

---

### Assessor ID

EES/024644

---

### Telephone

01455 883 250

---

### Email

[enquiries@elmhurstenergy.co.uk](mailto:enquiries@elmhurstenergy.co.uk)

---

## Assessment details

### Assessor's declaration

No related party

---

### Date of assessment

12 April 2023

---

## Date of certificate

13 April 2023

---

## Type of assessment

▶ [RdSAP](#)

---

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.