

# Energy performance certificate (EPC)

7 NEW STREET  
CHAGFORD  
TQ13 8BB

Energy rating

F

Valid until: 4 October 2030

Certificate number: 2490-9029-0322-3000-1003

Property type Mid-terrace house

Total floor area 72 square metres

## Rules on letting this property

### ! You may not be able to let this property

This property has an energy rating of F. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Properties can be let if they have an energy rating from A to E. You could make changes to [improve this property's energy rating](#).

## Energy rating and score

This property's energy rating is F. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		78 C
55-68	D		
39-54	E		
21-38	F	22 F	
1-20	G		

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Wall	Timber frame, as built, no insulation (assumed)	Very poor
Roof	Pitched, 270 mm loft insulation	Good
Roof	Pitched, 100 mm loft insulation	Average
Window	Single glazed	Very poor
Main heating	Room heaters, electric	Very poor
Main heating	Room heaters, dual fuel (mineral and wood)	Average
Main heating control	Programmer and appliance thermostats	Good
Main heating control	No thermostatic control of room temperature	Poor
Hot water	Electric immersion, standard tariff	Very poor
Lighting	Low energy lighting in 43% of fixed outlets	Average
Floor	Solid, no insulation (assumed)	N/A
Floor	To external air, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

### Primary energy use

The primary energy use for this property per year is 515 kilowatt hours per square metre (kWh/m<sup>2</sup>).

---

## How this affects your energy bills

An average household would need to spend **£2,145 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £1,333 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2020** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

---

### Heating this property

Estimated energy needed in this property is:

- 10,764 kWh per year for heating
- 2,748 kWh per year for hot water

---

### Impact on the environment

This property's environmental impact rating is F. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

#### Carbon emissions

An average household produces 6 tonnes of CO<sub>2</sub>

This property produces 6.7 tonnes of CO<sub>2</sub>

This property's potential production 2.7 tonnes of CO<sub>2</sub>

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

---

### Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Internal or external wall insulation	£4,000 - £14,000	£258
2. Floor insulation (suspended floor)	£800 - £1,200	£62
3. Floor insulation (solid floor)	£4,000 - £6,000	£58
4. Increase hot water cylinder insulation	£15 - £30	£95
5. Draught proofing	£80 - £120	£46

---

Step	Typical installation cost	Typical yearly saving
6. Low energy lighting	£20	£23
7. High heat retention storage heaters	£1,600 - £2,400	£560
8. Solar water heating	£4,000 - £6,000	£68
9. Replace single glazed windows with low-E double glazed windows	£3,300 - £6,500	£138
10. High performance external doors	£1,000	£25
11. Solar photovoltaic panels	£3,500 - £5,500	£374

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](http://www.gov.uk/improve-energy-efficiency).

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jackie French
Telephone	07832998460
Email	<a href="mailto:jackie@freerangeenergy.co.uk">jackie@freerangeenergy.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK
Assessor's ID	ECMK300653
Telephone	0333 123 1418
Email	<a href="mailto:info@ecmk.co.uk">info@ecmk.co.uk</a>

### About this assessment

Assessor's declaration	No related party
Date of assessment	5 October 2020
Date of certificate	5 October 2020
Type of assessment	<a href="#">RdSAP</a>