

# Energy performance certificate (EPC)

60 Lonsdale Street  
WORKINGTON  
CA14 2YD

Energy rating

**D**

Valid until: **11 March 2034**

Certificate number: **0717-3024-9207-6654-5200**

**Property type** Mid-terrace house

**Total floor area** 72 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy rating and score

This property's energy rating is D. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	<b>A</b>		
81-91	<b>B</b>		
69-80	<b>C</b>		78 <b>C</b>
55-68	<b>D</b>	55 <b>D</b>	
39-54	<b>E</b>		
21-38	<b>F</b>		
1-20	<b>G</b>		

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Wall	Cavity wall, as built, partial insulation (assumed)	Average
Roof	Pitched, no insulation (assumed)	Very poor
Roof	Flat, limited insulation (assumed)	Poor
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, mains gas	N/A

## Primary energy use

The primary energy use for this property per year is 383 kilowatt hours per square metre (kWh/m<sup>2</sup>).

▶ [About primary energy use](#)

## Additional information

Additional information about this property:

- Cavity fill is recommended
- Stone walls present, not insulated

## How this affects your energy bills

An average household would need to spend **£1,879 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £551 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Heating this property

Estimated energy needed in this property is:

- 12,684 kWh per year for heating
- 2,023 kWh per year for hot water

## Impact on the environment

This property's environmental impact rating is E. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

## Carbon emissions

An average household produces

6 tonnes of CO<sub>2</sub>

This property produces

4.8 tonnes of CO<sub>2</sub>

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Changes you could make

► [Do I need to follow these steps in order?](#)

## Step 1: Cavity wall insulation

Typical installation cost £500 - £1,500

Typical yearly saving £76

Potential rating after completing step 1 **56 D**

## Step 2: Internal or external wall insulation

Typical installation cost £4,000 - £14,000

Typical yearly saving £123

Potential rating after completing steps 1 and 2 **59 D**

## Step 3: Floor insulation (suspended floor)

Typical installation cost £800 - £1,200

Typical yearly saving £53

Potential rating after completing steps 1 to 3 **60 D**

## Step 4: Floor insulation (solid floor)

Typical installation cost £4,000 - £6,000

Typical yearly saving £47

Potential rating after completing steps 1 to 4 **61 D**

## Step 5: Heating controls (room thermostat)

Typical installation cost £350 - £450

Typical yearly saving £69

Potential rating after completing steps 1 to 5 **63 D**

## Step 6: Replace boiler with new condensing boiler

Typical installation cost £2,200 - £3,000

Typical yearly saving £125

Potential rating after completing steps 1 to 6 **66 D**

## Step 7: Solar water heating

Typical installation cost £4,000 - £6,000

Typical yearly saving £59

Potential rating after completing steps 1 to 7

67 D

## Step 8: Solar photovoltaic panels, 2.5 kWp

Typical installation cost £3,500 - £5,500

Typical yearly saving £565

Potential rating after completing steps 1 to 8

78 C

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

[Find ways to save energy in your home](#)

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Gary Gibson
Telephone	07540274933
Email	<a href="mailto:cumbriaepc@outlook.com">cumbriaepc@outlook.com</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/020883
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

## About this assessment

Assessor's declaration	No related party
Date of assessment	9 March 2024
Date of certificate	12 March 2024

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

**Certificate number**

[8205-4702-0029-7797-7743 \(/energy-certificate/8205-4702-0029-7797-7743\)](#)

**Expired on**

9 December 2023

---

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/hUnC3Xq1T4\)](https://forms.office.com/e/hUnC3Xq1T4) [Service performance \(/service-performance\)](#)

### **OGL**

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



[ght \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-c](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-c)